

Season B 200 no 08 / F200B048

HEPA Test Certificate



Smoke test according to EN1822-4:2009, Annex A

TEST DOP. ~~0.0211~~ %
TEST DOP 000.09

Filter Type

Model : HCG1113NKKM
Dimensions : 380X380X292 [mm]
Batch number : 2018038
Product number : 300-30182881-1H00091727

Nominal Technical Data

Air flow : 1550 [m³/h]
Pressure drop : 250 [Pa]
Penetration integral value : ≥ 99.95 [%]
Penetration local value : ≤ 0.25 [%]
Filterclass : H13 [EN1822:2009]

Details of Test Parameters

Air flow : 1550 [m³/h]
Flow velocity : 2.98 [m/s]
Test aerosol : Paraffin Oil
Mass concentration of test aerosol : 1.5 [g/m³]
Median particle diameter : 0.3-1.0 [μ m]

Testing Result

Product number : 300-30182881-1H00091727
Model : HCG1113NKKM
Date : 19/9/2018
Quality checker : HLL and LSS

Approved : Yes No

